

A	Select	Filter	Statistics	Answer Episodes	Re-generate Episodes	Legend	Help			
Page 1	[2]	[3]	[4]	[5]	[6]	[7]	[8]	[9]	[10]	[11]
<input type="checkbox"/>	All	Episode Name	Start Time	End Time	Type	Real Value	Value Limit	Status	By	
<input type="checkbox"/>		Pa Low Temp	03/14/2003 13:18:00	03/14/2003 13:58:00	Under Limit	1752.3	1753	Ans	2	
<input type="checkbox"/>		CCDC Opacity	03/14/2003 13:24:00	03/14/2003 13:29:00	Over Limit	14.8	14.7	Ans	1	
<input type="checkbox"/>		20 Minute SO2_Corrected Over Limit	03/14/2003 13:20:00	03/14/2003 13:39:00	Over Limit	863.5	862.5	Ans	MCDADETI	
<input type="checkbox"/>		Pa Low Temp	03/14/2003 13:19:00	03/14/2003 13:23:00	Invalid	0	0	Ans	2	
<input type="checkbox"/>		CCDC Opacity	03/14/2003 13:18:00	03/14/2003 13:23:00	Invalid	0	0	Ans	2	
<input type="checkbox"/>		edtest DownTime	03/14/2003 13:15:00	03/14/2003 13:29:00	Invalid	0	0	Ans	5	
<input type="checkbox"/>		Pa Low Temp	03/14/2003 13:00:00	03/14/2003 13:00:00	Under Limit	1752.5	1753	Ans	2	
<input type="checkbox"/>		CCDC Opacity	03/14/2003 12:42:00	03/14/2003 12:47:00	Over Limit	14.8	14.7	Ans	2	
<input type="checkbox"/>		20 Minute SO2_Corrected Over Limit	03/14/2003 12:48:00	03/14/2003 12:59:00	Over Limit	862.7	862.5	Ans	MCDADETI	
<input type="checkbox"/>		Pa Low Temp	03/14/2003 11:12:00	03/14/2003 11:12:00	Under Limit	1751.8	1753	Ans	2	
<input type="checkbox"/>		20 Minute SO2_Corrected Over Limit	03/14/2003 10:26:00	03/14/2003 10:39:00	Over Limit	862.8	862.5	Ans	2	
<input type="checkbox"/>		20 Minute SO2_Corrected Over Limit	03/14/2003 10:00:00	03/14/2003 10:19:00	Over Limit	863.6	862.5	Ans	2	
<input type="checkbox"/>		Pa Low Temp	03/14/2003 08:52:00	03/14/2003 08:52:00	Under Limit	1751.8	1753	Ans	2	
<input type="checkbox"/>		20 Minute SO2_Corrected Over Limit	03/14/2003 08:00:00	03/14/2003 08:19:00	Over Limit	862.7	862.5	Ans	2	
<input type="checkbox"/>		CCDC Opacity	03/14/2003 07:42:00	03/14/2003 07:47:00	Over Limit	14.8	14.7	Ans	2	
<input type="checkbox"/>		Pa Low Temp	03/14/2003	03/14/2003	Invalid	0	0	Ans	2	

FIG. 15

Answer Selected Episodes - Microsoft Internet Explorer

Data for Selected Episodes

Episode Name	Start Time	End Time	Type	Real Value	Value Limit	Status	Reason Code	Modification Time	Who
20 Minute SO2_Corrected Over Limit	03/14/2003 13:20:00	03/14/2003 13:39:00	Over Limit	863.5	862.5	Ans	16	10/26/2003 06:57:00	2

Answer all with this Reason: 16: Pn. Analyzer Malfunction

16: Pn. Analyzer Malfunction

Using this Corrective Action: Recalibrated Analyzer(s)

Recalibrated Analyzer(s)

Ok Cancel

FIG. 16